



SERVICE/INSTALLATION REPORT

SRIJANBHUMI INFOTECH PRIVATE LIMITED 3,CANAL STREET,2ND FLOOR,LOKNATH APPARTMENT,Kolkata-700014, West Bengal (State Code: 19) Mob: +91-033-40606427, Email: info@srijanbhumi.com GST NO.: 19AAOCS4406M1ZS WEBSITE: www.infotech.srijanbhumi.com		Service Report No:	Service Date: 07/03/2025
		Project/Order Reference:	
		Complaint No.:	Complaint Date:
		Site Address, Contact Person Name & Phone Number: Dr. B.C. Roy Engineering College . Durgapur, Paschim Bardhaman .	
Product Details with Sr. No.: Schnöder 10 KVA UPS S/N-9S2420A02004		Problem Details / Work Details: New installation.	
SPARES USED			
Sl No	Description Of Spares	Qty	FOC / Chargeable
Battery S/N-1	M0810040Y103455, 2	M0810040Y103477, 3	M0810040Y103451.
4	M0810040Y107728, 5	M0810046Y111020, 6	M0810040Y103473, 5
6	M0810046Y111018, 7	M0810046Y111019, 8	M0810046Y111039, 9
10	M0810046Y111028, 11	M0810046Y111025, 12	M0810040Y103460, 13
14	M0810046Y111038, 15	M0810040Y103478, 16	M0810046Y111012.
18	M0810040Y103455, 19	M0810040Y03562.	
TOTAL QUANTITY		TOTAL AMOUNT	
Engineer Name Priyodarsini Debnath.		Engineer In Time 	
CALL CLOSED/OPEN/IN PROGRESS: Closed.		Customer Payment Details (CASH/CHEQUE/NEFT DETAILS):	
Special Remarks/Information: Quanta 100AH, 18 NOS battery installation done ups (10KVA) input and output wire connection complete. Installation fully complete.		ENGINEER SIGNATURE WITH DATE For  07/03/25. Head Dept. Electronics & Comm. Engg. Dr. B. C. Roy Engineering College Durgapur	
		CUSTOMER SIGNATURE, DATE & SEAL	